


ELEVATION (SECTION A-A)



ELEVATION VIEW

GENERAL NOTES


- 1 1/2" CHAMFER ALL EXPOSED CORNERS.
- ADJUST WALL HEIGHT TO MATCH SLOPE OF FINAL GRADE.
- ADJUST REINFORCING FOR WALL HEIGHT.
- FOR FENCE DETAILS SEE STANDARD PLAN L-20.10-00.
- FOR CONCRETE STAIRWAY AND RAILING DETAILS SEE PLAN SHEET LIBRARY RD-12.
- THE CABINETS SHALL BE ATTACHED TO THE FOUNDATION WITH 4 EACH, 1/2"x8"x2"x4" HOT DIP GALVANIZED ANCHOR BOLTS, HOT DIP WASHERS AND HOT DIP NUTS. AS AN ALTERNATIVE, THE CABINETS SHALL BE ATTACHED TO THE FOUNDATION WITH STAINLESS STEEL EPOXY ANCHORS PER THE MANUFACTURER'S RECOMMENDATIONS. BOLTS SHALL EXTEND A MINIMUM OF 1-1/2" AND A MAXIMUM OF 2" ABOVE THE CONCRETE PAD.
- PLACE A 1/2" BEAD OF SILICONE BETWEEN CABINETS AND THE FOUNDATION.
- FOR GROUNDING DETAILS SEE STANDARD PLAN J-9A.
- INSTALL CONDUIT AS INDICATED IN PLANS. CONDUIT SHALL EXTEND 2" ABOVE THE FOUNDATION.
- CONCRETE SHALL BE CLASS 3000 FOR WALLS AND BASE.
- CONCRETE SHALL BE CLASS 4000 FOR STAIRS AND LANDINGS.

1 DRIVE GROUND RODS BEFORE PLACING CONCRETE. MOVE ROD(S) AND DRAIN TILE(S) WITH COVER(S) AS REQUIRED TO ACHIEVE FULL GROUND PENETRATION. MAINTAIN A 6" MINIMUM CLEARANCE BETWEEN GROUND RODS AS DETAILED ON STD. PLAN J-9a "TYPICAL GROUNDING DETAILS".

NOTE TO DESIGNER:



CHANGE PAGE REFERENCE NUMBERS BELOW TO BE JOB SPECIFIC. CEMENT CONCRETE STAIRWAY CONSTRUCTION DETAILS ARE STORED IN STANDARD PLANS- PLAN SHEET LIBRARY. INSERT CONCRETE STAIRWAY PLANSHEET IN CONTRACT AS CONTRACT SPECIFIC SHEET.

SEE SHEET 8.01 THROUGH 8.04 FOR CABINET ORIENTATIONS AND CONDUIT LAYOUTS



ELEVATION (SECTION B-B)

STAIRWAY CABINET FOUNDATION DETAIL (DUAL CABINET LAYOUT SHOWN)



ELEVATION VIEW

(TYPE D SERVICE CABINET & 332 CONTROLLER CABINET SHOWN)

FILE NAME	C:\AAWORK\control.e.dgn	REGION NO.	10	STATE	WASH	FED.AID PROJ.NO.		PLOT 5	8.05
TIME	6:22:18 AM	JOB NUMBER						SHEET 5 OF 5 SHEETS	
DATE	4/23/2009	CONTRACT NO.				LOCATION NO.			
PLOTTED BY	tr inhha	DATE	3-16-09	BY	JH				
DESIGNED BY		REVISION							
ENTERED BY		DATE	1-30-09	BY	JH				
CHECKED BY		REVISION							
PROJ. ENGR.	FINAL REVISIONS, TO SCALE	DATE	3-16-09	BY	JH				
REGIONAL ADM.	NEW SHT NO. COMBINE W 8.01 SERIES	DATE	1-30-09	BY	JH				



CABINET ORIENTATION, CONDUIT LAYOUT AND FOUNDATION WITH STAIRWAY DETAIL

ENGLISH